

ch 16 p673 ARJ

Fluid Fuel Reactors, 1958, Ch. 16
Lecture Notes, p1/3
Raluca Scarlat, January 2017

1500 F 815°C

1200 F 649°C

BeO moderated

Inconel tubes & vessel - 2" thick vessel - corrosion was unknown

Ø 52" 1.32 m

H 44" 1.12 m

for reflector/moderator only
coolant: liquid sodium

2 independent sodium loops
also used for decay heat
similarly cooled, in another
double radiator

fuel salt
finned tube radiator HX, tubes radiating to water tubes

← Helium coolant →

Control

fission chambers in reflectors
ionization chambers outside the RV

3 safety shim rods; 1 control rod

ANULUS
Helium circulating system
electrical heaters
on outer annulus

cools control & safety rods
warms up the core at S/A
by keeping temps isothermal
monitor for leakage

Drain tanks - kept heated
dry Helium - for moving salt around

Pumps - @ high point
↳ also expansion volume

Inconel - helium arc welding - inert gas shielded electric arc

Concrete pits below ground

Manual fuel injection $^{235}\text{UF}_4$ - NaF (molten)

Then covered with concrete blocks for shielding,

Carrier salt: NaF - ZrF_4 ✓ added to the carrier salt @ fuel pump bowl

61 kg ^{235}U → for criticality

384 g/L → ^{235}U concentration

38.8 L - core volume ⇒ 14.9 kg ^{235}U → critical mass

Reactivity coefficient - $(6) 10^{-5} (\Delta K/K) / ^\circ F$

↑
fuel expansion coefficient

↓ very fast
stabilized the core

> 200 kW → reactor was controlled on load following

Xenon

less than 5% ^{135}Xe retained in the fuel

expected: 27 hr operation ⇒ $(2) 10^{-3} \Delta K/K$ poisoning
if all Xe remained

1/4 of fuel inventory in the core

neutron energy > ^{135}Xe absorption resonances

detection limit: 5% of this poisoning

"Xe is not retained in the fuel"

~~none~~ was detected

leak

cover gas @ fuel pump

3wk
19 days
1wk
9d

Summary

96 MWh

fuel syst: 462 hr / 221 h
Na syst: 635 hr

3 days 74 h @ 11 MW.

26 d 42k
✓ DISMANTLED ✓